



**Grizzly Ranch Community Services District
Consumer Confidence Report
Water System
2020**

Grizzly Ranch Community Services District presents it's 2020 Consumer Confidence Report

The Consumer Confidence Report is produced annually to provide information on the quality of water provided to the Grizzly Ranch community. The report includes detailed information about the raw (untreated) water along with the treated water quality which was produced and distributed in the Calendar Year of 2020.

Grizzly Ranch CSD staff continues to work diligently in maintaining and operating the potable water system in the Grizzly Ranch community. Operational procedures are in place ensuring safe and quality drinking water is being produced and distributed as well as maintaining Regulatory compliance.

The Grizzly Ranch CSD staff and Board of Directors continue to focus on maintaining a reliable and safe drinking water system for the community which will provide confidence to its community members.

We encourage you to visit the Grizzly Ranch CSD website at: www.grizzlyranchcsd.com. The website contains information regarding meetings, financials and operations updates.

Thank you,

Grizzly Ranch CSD Board and Staff

2020 Consumer Confidence Report

Water System Information

Water System Name: Grizzly Ranch Community Services District

Report Date: 4/20/21

Type of Water Source(s) in Use: Wells

Name and General Location of Source(s): Well 3P2 – Fox Sparrow Dr., Well 9M – Fox Sparrow Dr., Well 1P – Yarrow Ln.

Drinking Water Source Assessment Information:

Time and Place of Regularly Scheduled Board Meetings for Public Participation: Grizzly Ranch CSD Board Meetings are scheduled on a Fiscal Year quarterly basis in the months of September, December, March and June. Meetings typically are scheduled on the third Tuesday of each month aside from June which is the fourth Tuesday. Meetings are typically scheduled at 9am. Due to COVID-19 limitations, regularly scheduled Board Meetings have been conducted remotely via zoom video and phone accessibility. Board Meeting schedules, agendas and minutes are available at: www.grizzlyranchcsd.com.

For More Information, Contact: Office Administrator Carol Logan or General Manager Aaron Corr at phone: 530-832-4716 or email: grizzlyranchcsd@gmail.com.

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2020 and may include earlier monitoring data.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Grizzly Ranch CSD a 4456 Grizzly Rd. Portola, CA. 96122, 530-832-4716 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Grizzly Ranch CSD 以获得中文的帮助: 4456 Grizzly Rd. Portola, CA 96122, 530-832-4716.

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Grizzly Ranch CSD, 4456 Grizzly Rd. Portola, CA. 96122 o tumawag sa 530-832-4716 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Grizzly Ranch CSD tại 4456 Grizzly Rd. Portola, CA. 96122, 530-832-4716 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Grizzly Ranch CSD ntawm 4456 Grizzly Rd. Portola, CA. 96122, 530-832-4716 rau kev pab hauv lus Askiv.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
Ppm	parts per million or milligrams per liter (mg/L)
Ppb	parts per billion or micrograms per liter (µg/L)

Term	Definition
Ppt	parts per trillion or nanograms per liter (ng/L)
Ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do

not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (State Total Coliform Rule)	(In a month) 0	0	1 positive monthly sample ^(a)	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (State Total Coliform Rule)	(In the year) 0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive	None	Human and animal fecal waste
<i>E. coli</i> (Federal Revised Total Coliform Rule)	(In the year) 0	0	(b)	0	Human and animal fecal waste

(a) Two or more positive monthly samples is a violation of the MCL

(b) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	7/14/2020 to 7/22/2020	5	.001	0	15	0.2	N/A	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	7/14/2020 to 7/22/20	5	.021	0	1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
								deposits; leaching from wood preservatives

Table 3. Sampling Results for Sodium and Hardness

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	4/14/2020	13		None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	4/14/2020	187		None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
See attachments for breakdowns						

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
See attachments for breakdowns						

--	--	--	--	--	--	--

Table 6. Detection of Unregulated Contaminants

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
See attachments for breakdowns					

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA’s Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Grizzly Ranch CSD is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Additional Special Language for Nitrate, Arsenic, Lead, Radon, and *Cryptosporidium*: [Enter Additional Information Described in Instructions for SWS CCR Document]

Federal Revised Total Coliform Rule (RTCR): [Enter Additional Information Described in Instructions for SWS CCR Document]

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A

For Water Systems Providing Groundwater as a Source of Drinking Water

Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	0	N/A	0	(0)	Human and animal fecal waste
Enterococci	0	N/A	TT	N/A	Human and animal fecal waste
Coliphage	0	N/A	TT	N/A	Human and animal fecal waste

Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT

Special Notice of Fecal Indicator-Positive Groundwater Source Sample: N/A

Special Notice for Uncorrected Significant Deficiencies: N/A

Table 9. Violation of Groundwater TT

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A

For Systems Providing Surface Water as a Source of Drinking Water

Table 10. Sampling Results Showing Treatment of Surface Water Sources

Treatment Technique ^(a) (Type of approved filtration technology used)	N/A
Turbidity Performance Standards ^(b) (that must be met through the water treatment process)	<p>Turbidity of the filtered water must:</p> <p>1 – Be less than or equal to [Enter Turbidity Performance Standard to Be Less Than or Equal to 95% of Measurements in a Month] NTU in 95% of measurements in a month.</p> <p>2 – Not exceed [Enter Turbidity Performance Standard Not to Be Exceeded for More Than Eight Consecutive Hours] NTU for more than eight consecutive hours.</p> <p>3 – Not exceed [Enter Turbidity Performance Standard Not to Be Exceeded at Any Time] NTU at any time.</p>
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	N/A
Highest single turbidity measurement during the year	N/A
Number of violations of any surface water treatment requirements	N/A

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

Summary Information for Violation of a Surface Water TT

Table 11. Violation of Surface Water TT

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A

Summary Information for Operating Under a Variance or Exemption

[Enter Additional Information Described in Instructions for SWS CCR Document]

Summary Information for Federal Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements

Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We did not find coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

During the past year we were required to conduct 0 Level 1 assessment(s). 0 Level 1 assessment(s) were completed. In addition, we were required to take 0 corrective actions and we completed 0 of these actions.

During the past year 0 Level 2 assessments were required to be completed for our water system. 0 Level 2 assessments were completed. In addition, we were required to take 0 corrective actions and we completed 0 of these actions.

[For Violation of the Total Coliform Bacteria TT Requirement, Enter Additional Information Described in Instructions for SWS CCR Document]

Level 2 Assessment Requirement Due to an *E. coli* MCL Violation

E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems. We did not find *E. coli* bacteria, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) identify problems and to correct any problems that were found during these assessments.

We were required to complete 0 Level 2 assessments because we did not *E. coli* in our water system. In addition, we were required to take 0 corrective actions and we completed 0 of these actions.

[For Violation of the *E. coli* TT Requirement, Enter Additional Information Described in Instructions for SWS CCR Document]

Attachment #1

**Grizzly Ranch CSD Lead and Copper Monitoring
History**

Lead and Copper Sample Summary Results

MP *	MP Begin	MP End	Type	# Samples	Measure	Units	Analyte Code/ Name	Begin Sampling	End Sampling
3Y2018-2020	01-01-2018	12-31-2020	90	5	0.021	MG/L	CU90 - COPPER SUMMARY	07-14-2020	07-22-2020
3Y2018-2020	01-01-2018	12-31-2020	90	5	0.001	MG/L	PB90 - LEAD SUMMARY	07-14-2020	07-22-2020
YR2007	01-01-2007	12-31-2007	90	5	0.129	MG/L	CU90 - COPPER SUMMARY	09-25-2007	09-25-2007
YR2007	01-01-2007	12-31-2007	90	5	0.019	MG/L	PB90 - LEAD SUMMARY	09-25-2007	09-25-2007
YR2008	01-01-2008	12-31-2008	90	5	0.213	MG/L	CU90 - COPPER SUMMARY	07-22-2008	07-22-2008
YR2008	01-01-2008	12-31-2008	90	5	0.012	MG/L	PB90 - LEAD SUMMARY	07-22-2008	07-22-2008
YR2009	01-01-2009	12-31-2009	90	5	0.182	MG/L	CU90 - COPPER SUMMARY	09-10-2009	09-10-2009
YR2009	01-01-2009	12-31-2009	90	5	0.023	MG/L	PB90 - LEAD SUMMARY	09-10-2009	09-10-2009
YR2010	01-01-2010	12-31-2010	90	5	0.314	MG/L	CU90 - COPPER SUMMARY	07-20-2010	07-20-2010
YR2010	01-01-2010	12-31-2010	90	5	0.026	MG/L	PB90 - LEAD SUMMARY	07-20-2010	07-20-2010
YR2011	01-01-2011	12-31-2011	90	5	0.127	MG/L	CU90 - COPPER SUMMARY	09-09-2011	09-09-2011
YR2011	01-01-2011	12-31-2011	90	5	0.017	MG/L	PB90 - LEAD SUMMARY	09-09-2011	09-09-2011
YR2013	01-01-2013	12-31-2013	90	5	0.431	MG/L	CU90 - COPPER SUMMARY	09-24-2013	09-24-2013
YR2013	01-01-2013	12-31-2013	90	5	0.014	MG/L	PB90 - LEAD SUMMARY	09-24-2013	09-24-2013
YR2014	01-01-2014	12-31-2014	90	5	0.555	MG/L	CU90 - COPPER SUMMARY	09-16-2014	10-24-2014
YR2014	01-01-2014	12-31-2014	90	5	0.007	MG/L	PB90 - LEAD SUMMARY	09-16-2014	10-24-2014
YR2017	01-01-2017	12-31-2017	90	5	0.118	MG/L	CU90 - COPPER SUMMARY	07-08-2017	07-12-2017
YR2017	01-01-2017	12-31-2017	90	5	0	MG/L	PB90 -	07-08-2017	07-12-2017

Attachment #2

GRCSD

Well 9M

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 3205006

NAME: GRIZZLY RANCH CSD

COUNTY: PLUMAS

SOURCE NO: 003

NAME: WELL 9M

CLASS: CTGP

STATUS: Active

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	COUNT	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	
3205006 - 003	GRIZZLY RANCH CSD		003	WELL 9M								
	GP SECONDARY/GP											
	00440	BICARBONATE ALKALINITY	190	MG/L	-----	-----	2016/08/16	3	108		2025/08	
	00916	CALCIUM	62	MG/L	-----	-----	2016/08/16	4	108		2025/08	
	00445	CARBONATE ALKALINITY	<	10	MG/L	-----	-----	2016/08/16	3	108		2025/08
	00940	CHLORIDE	3	MG/L	500	-----	2016/08/16	3	108		2025/08	
	00081	COLOR	<	5	UNITS	15	-----	2016/08/16	3	108		2025/08
	01042	COPPER	<	10	UG/L	1000	50	2016/08/16	3	108		2025/08
	38260	FOAMING AGENTS (MBAS)	<	0.1	MG/L	.5	-----	2016/08/16	3	108		2025/08
	00900	HARDNESS (TOTAL) AS CaCO3	208	MG/L	-----	-----	2016/08/16	4	108		2025/08	
	71830	HYDROXIDE ALKALINITY	<	10	MG/L	-----	-----	2016/08/16	3	108		2025/08
	01045	IRON	8630	UG/L	300	100	2021/01/12	34	3	M	2021/04	
	00927	MAGNESIUM	13	MG/L	-----	-----	2016/08/16	4	108		2025/08	
	01055	MANGANESE	800	UG/L	50	20	2021/01/12	34	3	M	2021/04	
	00086	ODOR THRESHOLD @ 60 C	<	1	TON	3	1	2016/08/16	3	108		2025/08
	00403	PH, LABORATORY	6.8		-----	-----	2016/08/16	3	108		2025/08	
	01077	SILVER	<	1	UG/L	100	10	2016/08/16	3	108		2025/08
	00929	SODIUM	13	MG/L	-----	-----	2016/08/16	3	108		2025/08	
	00095	SPECIFIC CONDUCTANCE	487	US	1600	-----	2016/08/16	3	108		2025/08	
	00945	SULFATE	84.6	MG/L	500	.5	2016/08/16	3	108		2025/08	
	70300	TOTAL DISSOLVED SOLIDS	320	MG/L	1000	-----	2016/08/16	3	108		2025/08	
	82079	TURBIDITY, LABORATORY	10.1	NTU	5	.1	2016/08/16	3	108		2025/08	
	01092	ZINC	2700	UG/L	5000	50	2016/08/16	3	108		2025/08	
	IO INORGANIC											
	01105	ALUMINUM	<	10	UG/L	1000	50	2016/08/16	3	108		2025/08
	01097	ANTIMONY	<	1	UG/L	6	6	2016/08/16	3	108		2025/08
	01002	ARSENIC	<	2	UG/L	10	2	2021/01/12	34	108		2030/01

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 3205006

NAME: GRIZZLY RANCH CSD

COUNTY: PLUMAS

SOURCE NO:

NAME: WELL 9M

CLASS: CTGP

STATUS: Active

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	COUNT	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES
3205006 - IO 003	INORGANIC										
01007	BARIUM	<	0.2 UG/L	1000	100	2016/08/16	3	108		2025/08	
01012	BERYLLIUM	<	1 UG/L	4	1	2016/08/16	3	108		2025/08	
01027	CADMIUM	<	0.2 UG/L	5	1	2016/08/16	3	108		2025/08	
01034	CHROMIUM (TOTAL)	<	1 UG/L	50	10	2016/08/16	3	108		2025/08	
00951	FLUORIDE (F) (NATURAL-SOURCE)	<	0.1 MG/L	2	.1	2016/08/16	3	108		2025/08	
71900	MERCURY	<	0.02 UG/L	2	1	2016/08/16	3	108		2025/08	
01067	NICKEL	<	1 UG/L	100	10	2016/08/16	3	108		2025/08	
A-031	PERCHLORATE	<	4 UG/L	6	4	2019/04/09	4	36		2022/04	
01147	SELENIUM	<	1 UG/L	50	5	2016/08/16	3	108		2025/08	
01059	THALLIUM	<	0.2 UG/L	2	1	2016/08/16	3	108		2025/08	
NI	NITRATE/NITRITE										
00618	NITRATE (AS N)	<	0.4 mg/L	10	.4	2020/04/14	7	12		2021/04	
00620	NITRITE (AS N)	<	0.4 mg/L	1	.4	2019/04/09	4	36		2022/04	
RA	RADIOLOGICAL										
01501	GROSS ALPHA		0.712 PCI/L	15	3	2016/08/16	3	108		2025/08	
11501	RADIUM 228		1 PCI/L	-----	1	2017/02/14	4	108		2026/02	
S1	REGULATED VOC										
34506	1,1,1-TRICHLOROETHANE	<	0.5 UG/L	200	.5	2019/04/09	3	72		2025/04	
34516	1,1,2,2-TETRACHLOROETHANE	<	0.5 UG/L	1	.5	2019/04/09	3	72		2025/04	
34511	1,1,2-TRICHLOROETHANE	<	0.5 UG/L	5	.5	2019/04/09	3	72		2025/04	
34496	1,1-DICHLOROETHANE	<	0.5 UG/L	5	.5	2019/04/09	3	72		2025/04	
34501	1,1-DICHLOROETHYLENE	<	0.5 UG/L	6	.5	2019/04/09	3	72		2025/04	
34551	1,2,4-TRICHLOROBENZENE	<	0.5 UG/L	5	.5	2019/04/09	3	72		2025/04	
34536	1,2-DICHLOROBENZENE	<	0.5 UG/L	600	.5	2019/04/09	3	72		2025/04	
34531	1,2-DICHLOROETHANE	<	0.5 UG/L	.5	.5	2019/04/09	3	72		2025/04	

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: NAME: COUNTY:
 SOURCE NO: NAME: CLASS: STATUS:

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	COUNT	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES
3205006 - 003	S1 34541 1,2-DICHLOROPROPANE	<	0.5 UG/L	5	.5	2019/04/09	3	72		2025/04	
	34561 1,3-DICHLOROPROPENE (TOTAL)	<	0.5 UG/L	.5	.5	2019/04/09	3	72		2025/04	
	34571 1,4-DICHLOROBENZENE	<	0.5 UG/L	5	.5	2019/04/09	3	72		2025/04	
	34030 BENZENE	<	0.5 UG/L	1	.5	2019/04/09	3	72		2025/04	
	32102 CARBON TETRACHLORIDE	<	0.5 UG/L	.5	.5	2019/04/09	3	72		2025/04	
	77093 CIS-1,2-DICHLOROETHYLENE	<	0.5 UG/L	6	.5	2019/04/09	3	72		2025/04	
	34423 DICHLOROMETHANE	<	0.5 UG/L	5	.5	2019/04/09	3	72		2025/04	
	34371 ETHYL BENZENE	<	0.5 UG/L	300	.5	2019/04/09	3	72		2025/04	
	46491 METHYL-TERT-BUTYL-ETHER (MTBE)	<	3.0 UG/L	13	3	2019/04/09	3	72		2025/04	
	34301 MONOCHLOROBENZENE	<	0.5 UG/L	70	.5	2019/04/09	3	72		2025/04	
	77128 STYRENE	<	0.5 UG/L	100	.5	2019/04/09	3	72		2025/04	
	34475 TETRACHLOROETHYLENE	<	0.5 UG/L	5	.5	2019/04/09	3	72		2025/04	
	34010 TOLUENE	<	0.5 UG/L	150	.5	2019/04/09	3	72		2025/04	
	34546 TRANS-1,2-DICHLOROETHYLENE	<	0.5 UG/L	10	.5	2019/04/09	3	72		2025/04	
	39180 TRICHLOROETHYLENE	<	0.5 UG/L	5	.5	2019/04/09	3	72		2025/04	
	34488 TRICHLOROFLUOROMETHANE FREON 11	<	5 UG/L	150	5	2019/04/09	3	72		2025/04	
81611 TRICHLOROTRIFLUOROETHANE (FREON 113)	<	10 UG/L	1200	10	2019/04/09	3	72		2025/04		
39175 VINYL CHLORIDE	<	0.5 UG/L	.5	.5	2019/04/09	3	72		2025/04		
81551 XYLENES (TOTAL)	<	0.5 UG/L	1750	0.5	2019/04/09	3	72		2025/04		

Attachment #3

GRCSD Well 3P2

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 3205006

NAME: GRIZZLY RANCH CSD

COUNTY: PLUMAS

SOURCE NO: 002

NAME: WELL 3P2

CLASS: CTGP

STATUS: Active

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	COUNT	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES
3205006 - 002	GRIZZLY RANCH CSD	002	WELL 3P2								
	GP SECONDARY/GP										
00440	BICARBONATE ALKALINITY	170	MG/L	-----	-----	2020/04/14	5	108		2029/04	
00916	CALCIUM	47	MG/L	-----	-----	2020/04/14	4	108		2029/04	
00445	CARBONATE ALKALINITY	< 10	MG/L	-----	-----	2020/04/14	5	108		2029/04	
00940	CHLORIDE	2	MG/L	500	-----	2020/04/14	5	108		2029/04	
00081	COLOR	5.0000	UNITS	15	-----	2014/07/08	3	108		2023/07	
01042	COPPER	< 50	UG/L	1000	50	2020/04/14	5	108		2029/04	
38260	FOAMING AGENTS (MBAS)	< 0.05	MG/L	.5	-----	2020/04/14	5	108		2029/04	
00900	HARDNESS (TOTAL) AS CaCO3	187	MG/L	-----	-----	2020/04/14	5	108		2029/04	
71830	HYDROXIDE ALKALINITY	< 10	MG/L	-----	-----	2020/04/14	5	108		2029/04	
01045	IRON	7440	UG/L	300	100	2021/01/12	64	3	M	2021/04	
00927	MAGNESIUM	17	MG/L	-----	-----	2020/04/14	4	108		2029/04	
01055	MANGANESE	300	UG/L	50	20	2021/01/12	64	3	M	2021/04	
00086	ODOR THRESHOLD @ 60 C	32.0000	TON	3	1	2014/07/08	4	108		2023/07	
00403	PH, LABORATORY	6.9000		-----	-----	2011/07/26	4	108		2020/07	DUE NOW SEE ATTACHMENT: A
01077	SILVER	< 1.0000	UG/L	100	10	2014/07/08	4	108		2023/07	
00929	SODIUM	13	MG/L	-----	-----	2020/04/14	4	108		2029/04	
00095	SPECIFIC CONDUCTANCE	456	US	1600	-----	2020/04/14	5	108		2029/04	
00945	SULFATE	80.3	MG/L	500	.5	2020/04/14	5	108		2029/04	
70300	TOTAL DISSOLVED SOLIDS	280	MG/L	1000	-----	2020/04/14	5	108		2029/04	
82079	TURBIDITY, LABORATORY	52.7000	NTU	5	.1	2014/07/08	3	108		2023/07	
01092	ZINC	< 50	UG/L	5000	50	2020/04/14	5	108		2029/04	
	IO INORGANIC										
01105	ALUMINUM	50.0000	UG/L	1000	50	2014/07/08	4	108		2023/07	
01097	ANTIMONY	< 1.0000	UG/L	6	6	2014/07/08	4	108		2023/07	
01002	ARSENIC	< 2	UG/L	10	2	2021/01/12	64	108		2030/01	

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 3205006

NAME: GRIZZLY RANCH CSD

COUNTY: PLUMAS

SOURCE NO:

NAME: WELL 3P2

CLASS: CTGP

STATUS: Active

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	COUNT	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES
3205006 - 002	IO INORGANIC										
	01007	BARIUM	63.2000	UG/L	1000	100	2014/07/08	4	108		2023/07
	01012	BERYLLIUM	< .2000	UG/L	4	1	2014/07/08	4	108		2023/07
	01027	CADMIUM	< .2000	UG/L	5	1	2014/07/08	4	108		2023/07
	01034	CHROMIUM (TOTAL)	5.0000	UG/L	50	10	2014/07/08	4	108		2023/07
	00951	FLUORIDE (F) (NATURAL-SOURCE)	< 0.1	MG/L	2	.1	2020/04/14	5	108		2029/04
	71900	MERCURY	.0600	UG/L	2	1	2014/07/08	4	108		2023/07
	01067	NICKEL	3.0000	UG/L	100	10	2014/07/08	4	108		2023/07
	A-031	PERCHLORATE	< 4	UG/L	6	4	2019/04/09	12	36		2022/04
	01147	SELENIUM	< 1.0000	UG/L	50	5	2014/07/08	4	108		2023/07
01059	THALLIUM	< .2000	UG/L	2	1	2014/07/08	4	108		2023/07	
	NI NITRATE/NITRITE										
	00618	NITRATE (AS N)	< 0.4	mg/L	10	.4	2020/04/14	13	12		2021/04
	00620	NITRITE (AS N)	< 0.4	mg/L	1	.4	2020/04/14	6	36		2023/04
	RA RADIOLOGICAL										
	01501	GROSS ALPHA	0.637	PCI/L	15	3	2016/01/12	5	108		2025/01
	11501	RADIUM 228	1	PCI/L	-----	1	2017/02/14	6	108		2026/02
	S1 REGULATED VOC										
	34506	1,1,1-TRICHLOROETHANE	< 0.5	UG/L	200	.5	2020/07/14	4	72		2026/07
	34516	1,1,2,2-TETRACHLOROETHANE	< 0.5	UG/L	1	.5	2020/07/14	4	72		2026/07
	34511	1,1,2-TRICHLOROETHANE	< 0.5	UG/L	5	.5	2020/07/14	4	72		2026/07
	34496	1,1-DICHLOROETHANE	< 0.5	UG/L	5	.5	2020/07/14	4	72		2026/07
	34501	1,1-DICHLOROETHYLENE	< 0.5	UG/L	6	.5	2020/07/14	4	72		2026/07
	34551	1,2,4-TRICHLOROBENZENE	< 0.5	UG/L	5	.5	2020/07/14	4	72		2026/07
	34536	1,2-DICHLOROBENZENE	< 0.5	UG/L	600	.5	2020/07/14	4	72		2026/07
	34531	1,2-DICHLOROETHANE	< 0.5	UG/L	.5	.5	2020/07/14	4	72		2026/07

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: NAME: COUNTY:
 SOURCE NO: NAME: CLASS: STATUS:

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	COUNT	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES
3205006 - S1002	34541 1,2-DICHLOROPROPANE	<	0.5 UG/L	5	.5	2020/07/14	4	72		2026/07	
	34561 1,3-DICHLOROPROPENE (TOTAL)	<	0.5 UG/L	.5	.5	2020/07/14	4	72		2026/07	
	34571 1,4-DICHLOROBENZENE	<	0.5 UG/L	5	.5	2020/07/14	4	72		2026/07	
	34030 BENZENE	<	0.5 UG/L	1	.5	2020/07/14	4	72		2026/07	
	32102 CARBON TETRACHLORIDE	<	0.5 UG/L	.5	.5	2020/07/14	4	72		2026/07	
	77093 CIS-1,2-DICHLOROETHYLENE	<	0.5 UG/L	6	.5	2020/07/14	4	72		2026/07	
	34423 DICHLOROMETHANE	<	0.5 UG/L	5	.5	2020/07/14	4	72		2026/07	
	34371 ETHYL BENZENE	<	0.5 UG/L	300	.5	2020/07/14	4	72		2026/07	
	46491 METHYL-TERT-BUTYL-ETHER (MTBE)	<	3.0 UG/L	13	3	2020/07/14	4	72		2026/07	
	34301 MONOCHLOROBENZENE	<	0.5 UG/L	70	.5	2020/07/14	4	72		2026/07	
	77128 STYRENE	<	0.5 UG/L	100	.5	2020/07/14	4	72		2026/07	
	34475 TETRACHLOROETHYLENE	<	0.5 UG/L	5	.5	2020/07/14	4	72		2026/07	
	34010 TOLUENE	<	0.5 UG/L	150	.5	2020/07/14	4	72		2026/07	
	34546 TRANS-1,2-DICHLOROETHYLENE	<	0.5 UG/L	10	.5	2020/07/14	4	72		2026/07	
	39180 TRICHLOROETHYLENE	<	0.5 UG/L	5	.5	2020/07/14	4	72		2026/07	
	34488 TRICHLOROFLUOROMETHANE FREON 11	<	5 UG/L	150	5	2020/07/14	4	72		2026/07	
	81611 TRICHLOROTRIFLUOROETHANE (FREON 113)	<	10 UG/L	1200	10	2020/07/14	4	72		2026/07	
	39175 VINYL CHLORIDE	<	0.5 UG/L	.5	.5	2020/07/14	4	72		2026/07	
81551 XYLENES (TOTAL)	<	0.5 UG/L	1750	0.5	2020/07/14	4	72		2026/07		

GRCSD Well 3P2
Attachment: A



INORGANIC CHEMICALS ANALYSIS

Date of Report : February 10, 2021 Sample ID : CH 2072526-001
 Laboratory Name : **FGL Environmental** Approved By **Kelly A. Dunnahoo, B.S.** Digitally signed by Kelly A. Dunnahoo, B.S.
Title: Laboratory Director
Date: 2021-02-10
 Sampled On : 04/14/2020-11:27
 Received On : 04/14/2020-16:00 Sampler : Stephen Semple
 Completed On : 04/29/2020-15:33 Employed By : FGL Environmental

System Name : GRIZZLY RANCH CSD Number : 3205006-002 **EDT**
 Name Or Number of Sample Source : WELL 3P2

User ID	: 32C	Station Number	: 3205006-002
Date/Time of Sample	: 2004141127 YYMMDDTTTT	Laboratory Code	: 2 6 7 0
Submitted By	: FGL Environmental	Lab Location	: Chico, CA
		Phone #	: (530) 343-5818

GENERAL MINERAL & PHYSICAL

TEST	MCL	UNITS	CHEMICALS	ENTRY	RESULT	DLR
4500HB		Std	pH	00403	6.5	
		Units				
2120B	15 ²	Units	Apparent Color (Unfiltered)	00081	ND	5
2150B	3 ²	TON	Odor Threshold at 60 °C	00086	ND	1
2130B	5 ²	NTU	Lab Turbidity	82079	6.8	0.1

ADDITIONAL INORGANIC

TEST	MCL	UNITS	CHEMICALS	ENTRY	RESULT	DLR
4500HB			Langelier Index at 20 °C	71814	-1.1	
4500HB			Aggressiveness Index	82383	10.7	

MCL - Maximum Contaminant Level, DLR -Detection Limit for Reporting Purpose,
² Indicates Secondary Drinking Water Standards(Recommended-Upper-Short Term)

ND - Not Detected at or above DLR

February 10, 2021
Grizzly Ranch CSD

Lab ID : CH 2072526
 Customer : 7-9323

Inorganic - Wet Chemistry QC

2120B	04/15/2020:710643 All analysis quality controls are within established criteria.
	04/15/2020:710491 All preparation quality controls are within established criteria (performed at FGL-CH ELAP# 2670).
2130B	04/15/2020:710638 All analysis quality controls are within established criteria.
	04/15/2020:710486 All preparation quality controls are within established criteria (performed at FGL-CH ELAP# 2670).
2150B	04/15/2020:710489 All preparation quality controls are within established criteria (performed at FGL-CH ELAP# 2670).
2320B	04/22/2020:206294 All analysis quality controls are within established criteria.
	04/22/2020:204482 All preparation quality controls are within established criteria (performed at FGL-SP ELAP# 1573).
2510B	04/23/2020:206261 All analysis quality controls are within established criteria.
	04/23/2020:204515 All preparation quality controls are within established criteria (performed at FGL-SP ELAP# 1573).
2540CE	04/16/2020:204210 All preparation quality controls are within established criteria (performed at FGL-SP ELAP# 1573).
300.0	04/16/2020:205774 All analysis quality controls are within established criteria.
	04/15/2020:204187 All preparation quality controls are within established criteria (performed at FGL-SP ELAP# 1573).
4500-H B	04/14/2020:710482 All preparation quality controls are within established criteria (performed at FGL-CH ELAP# 2670).
4500HB	04/14/2020:710633 All analysis quality controls are within established criteria.
4500NO2B	04/15/2020:205747 All analysis quality controls are within established criteria.
	04/15/2020:204166 All preparation quality controls are within established criteria (performed at FGL-SP ELAP# 1573).
5540C	04/16/2020:206461 All analysis quality controls are within established criteria.
	04/16/2020:204661 All preparation quality controls are within established criteria (performed at FGL-SP ELAP# 1573).

Discussion of Analytical Results: -

Amended Report - 02/10/2021 - Amended to include the laboratory pH and case narrative note.

February 10, 2021
Grizzly Ranch CSD

Lab ID : CH 2072526
Customer : 7-9323

Discussion of Analytical Results: Continued...

Case Narrative - 02/10/2021 - The laboratory pH was analyzed past method holding time.

Certification: I certify that this data package is in compliance with ELAP standards, both technically and for completeness, except for any conditions listed above. Release of the data contained in this data package is authorized by the Laboratory Director or his designee, as verified by the following electronic signature.

KD:DMB

Approved By **Kelly A. Dunnahoo, B.S.**



Digitally signed by Kelly A. Dunnahoo, B.S.
Title: Laboratory Director
Date: 2021-02-10

Attachment #4

GRCSD Well 1P

- **Well 1P is offline of the Water Treatment System**
- **Well 1P has been disabled since October 2020**

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 3205006

NAME: GRIZZLY RANCH CSD

COUNTY: PLUMAS

SOURCE NO: 001

NAME: WELL 1P

CLASS: CTGP

STATUS: Active

PCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	COUNT	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	
3205006 - 001	GRIZZLY RANCH CSD		001	WELL 1P								
	GP SECONDARY/GP											
	00440	BICARBONATE ALKALINITY	80	MG/L	-----	-----	2017/04/18	4	108		2026/04	
	00916	CALCIUM	302	MG/L	-----	-----	2017/04/18	4	108		2026/04	
	00445	CARBONATE ALKALINITY	<	10	MG/L	-----	-----	2017/04/18	4	108		2026/04
	00940	CHLORIDE	4	MG/L	500	-----	2017/04/18	4	108		2026/04	
	00081	COLOR	<	5	UNITS	15	-----	2020/04/14	4	108		2029/04
	01042	COPPER	<	50	UG/L	1000	50	2017/04/18	5	108		2026/04
	38260	FOAMING AGENTS (MBAS)	<	0.05	MG/L	.5	-----	2017/04/18	4	108		2026/04
	00900	HARDNESS (TOTAL) AS CaCO3	832	MG/L	-----	-----	2017/04/18	4	108		2026/04	
	71830	HYDROXIDE ALKALINITY	<	10	MG/L	-----	-----	2017/04/18	4	108		2026/04
	01045	IRON	100	UG/L	300	100	2020/07/14	65	3	M	2020/10	DUE NOW
	00927	MAGNESIUM	19	MG/L	-----	-----	2017/04/18	4	108		2026/04	
	01055	MANGANESE	230	UG/L	50	20	2020/07/14	65	3	M	2020/10	DUE NOW
	00086	ODOR THRESHOLD @ 60 C	<	1	TON	3	1	2020/04/14	4	108		2029/04
	00403	PH, LABORATORY	6.8		-----	-----	2017/04/18	4	108		2026/04	
	01077	SILVER	<	10	UG/L	100	10	2017/04/18	5	108		2026/04
	00929	SODIUM	44	MG/L	-----	-----	2017/04/18	4	108		2026/04	
	00095	SPECIFIC CONDUCTANCE	1530	US	1600	-----	2017/04/18	4	108		2026/04	
	00945	SULFATE	798	MG/L	500	.5	2017/04/18	4	108		2026/04	
	70300	TOTAL DISSOLVED SOLIDS	1340	MG/L	1000	-----	2017/04/18	4	108		2026/04	
	82079	TURBIDITY, LABORATORY	0.3	NTU	5	.1	2020/04/14	4	108		2029/04	
	01092	ZINC	320	UG/L	5000	50	2017/04/18	5	108		2026/04	
	IO INORGANIC											
	01105	ALUMINUM	50	UG/L	1000	50	2017/04/18	5	108		2026/04	
	01097	ANTIMONY	<	6	UG/L	6	6	2017/04/18	5	108		2026/04
	01002	ARSENIC	24	UG/L	10	2	2020/07/14	67	3	M	2020/10	DUE NOW

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 3205006

NAME: GRIZZLY RANCH CSD

COUNTY: PLUMAS

SOURCE NO:

NAME: WELL 1P

CLASS: CTGP

STATUS: Active

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	COUNT	FREQ MON THS	MOD	NEXT SAMPLE DJE	NOTES	
3205006 - 001	IO INORGANIC											
	01007	BARIUM	<	100 UG/L	1000	100	2017/04/18	5	108		2026/04	
	01012	BERYLLIUM	<	1 UG/L	4	1	2017/04/18	5	108		2026/04	
	01027	CADMIUM	<	1 UG/L	5	1	2017/04/18	5	108		2026/04	
	01034	CHROMIUM (TOTAL)	<	10 UG/L	50	10	2017/04/18	5	108		2026/04	
	00951	FLUORIDE (F) (NATURAL-SOURCE)		0.2 MG/L	2	.1	2017/04/18	4	108		2026/04	
	71900	MERCURY	<	1 UG/L	2	1	2017/04/18	5	108		2026/04	
	01067	NICKEL	<	10 UG/L	100	10	2017/04/18	5	108		2026/04	
	A-031	PERCHLORATE	<	4 UG/L	6	4	2019/04/09	7	36		2022/04	
	01147	SELENIUM	<	5 UG/L	50	5	2017/04/18	5	108		2026/04	
01059	THALLIUM	<	1 UG/L	2	1	2017/04/18	5	108		2026/04		
NI	NITRATE/NITRITE											
	00618	NITRATE (AS N)	<	0.4 mg/L	10	.4	2020/04/14	15	12		2021/04	
00620	NITRITE (AS N)	<	0.4 mg/L	1	.4	2020/04/14	8	36		2023/04		
RA	RADIOLOGICAL											
	01501	GROSS ALPHA		1.17 PCI/L	15	3	2020/04/14	6	108		2029/04	
11501	RADIUM 228	<	.0000 PCI/L	-----	1	2014/01/07	5	108		2023/01		
S1	REGULATED VOC											
	34506	1,1,1-TRICHLOROETHANE	<	0.5 UG/L	200	.5	2020/07/14	4	72		2026/07	
	34516	1,1,2,2-TETRACHLOROETHANE	<	0.5 UG/L	1	.5	2020/07/14	4	72		2026/07	
	34511	1,1,2-TRICHLOROETHANE	<	0.5 UG/L	5	.5	2020/07/14	4	72		2026/07	
	34496	1,1-DICHLOROETHANE	<	0.5 UG/L	5	.5	2020/07/14	4	72		2026/07	
	34501	1,1-DICHLOROETHYLENE	<	0.5 UG/L	6	.5	2020/07/14	4	72		2026/07	
	34551	1,2,4-TRICHLOROBENZENE	<	0.5 UG/L	5	.5	2020/07/14	4	72		2026/07	
	34536	1,2-DICHLOROBENZENE	<	0.5 UG/L	600	.5	2020/07/14	4	72		2026/07	
	34531	1,2-DICHLOROETHANE	<	0.5 UG/L	.5	.5	2020/07/14	4	72		2026/07	

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO:

NAME:

COUNTY:

SOURCE NO:

NAME:

CLASS:

STATUS:

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	COUNT	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES
3205006 - 001	S1 34541 1,2-DICHLOROPROPANE	<	0.5 UG/L	5	.5	2020/07/14	4	72		2026/07	
	34561 1,3-DICHLOROPROPENE (TOTAL)	<	0.5 UG/L	.5	.5	2020/07/14	4	72		2026/07	
	34571 1,4-DICHLOROBENZENE	<	0.5 UG/L	5	.5	2020/07/14	4	72		2026/07	
	34030 BENZENE	<	0.5 UG/L	1	.5	2020/07/14	4	72		2026/07	
	32102 CARBON TETRACHLORIDE	<	0.5 UG/L	.5	.5	2020/07/14	4	72		2026/07	
	77093 CIS-1,2-DICHLOROETHYLENE	<	0.5 UG/L	6	.5	2020/07/14	4	72		2026/07	
	34423 DICHLOROMETHANE	<	0.5 UG/L	5	.5	2020/07/14	4	72		2026/07	
	34371 ETHYL BENZENE	<	0.5 UG/L	300	.5	2020/07/14	4	72		2026/07	
	46491 METHYL-TERT-BUTYL-ETHER (MTBE)	<	3.0 UG/L	13	3	2020/07/14	4	72		2026/07	
	34301 MONOCHLOROBENZENE	<	0.5 UG/L	70	.5	2020/07/14	4	72		2026/07	
	77128 STYRENE	<	0.5 UG/L	100	.5	2020/07/14	4	72		2026/07	
	34475 TETRACHLOROETHYLENE	<	0.5 UG/L	5	.5	2020/07/14	4	72		2026/07	
	34010 TOLUENE	<	0.5 UG/L	150	.5	2020/07/14	4	72		2026/07	
	34546 TRANS-1,2-DICHLOROETHYLENE	<	0.5 UG/L	10	.5	2020/07/14	4	72		2026/07	
	39180 TRICHLOROETHYLENE	<	0.5 UG/L	5	.5	2020/07/14	4	72		2026/07	
	34488 TRICHLOROFLUOROMETHANE FREON 11	<	5 UG/L	150	5	2020/07/14	4	72		2026/07	
	81611 TRICHLOROTRIFLUOROETHANE (FREON 113)	<	10 UG/L	1200	10	2020/07/14	4	72		2026/07	
	39175 VINYL CHLORIDE	<	0.5 UG/L	.5	.5	2020/07/14	4	72		2026/07	
	81551 XYLENES (TOTAL)	<	0.5 UG/L	1750	0.5	2020/07/14	4	72		2026/07	