



Grizzly Ranch Community Services District
Consumer Confidence Report
Water System
2021

2021 Consumer Confidence Report

Water System Information

Water System Name: Grizzly Ranch Community Services District

Report Date: 6/14/21

Type of Water Source(s) in Use: Wells

Name and General Location of Source(s): Well 3P2 – Fox Sparrow Dr., Well 9M – Fox Sparrow Dr., Well 1P – Yarrow Ln.

Drinking Water Source Assessment Information:

Time and Place of Regularly Scheduled Board Meetings for Public Participation: Grizzly Ranch CSD Board Meetings are scheduled on a Fiscal Year quarterly basis in the months of September, December, March and June. Meetings typically are scheduled on the third Tuesday of each month. Meetings are typically scheduled at 10am. Regularly scheduled Board Meetings have been conducted remotely in hybrid fashion via zoom video and phone accessibility. Board Meeting schedules, agendas and minutes are available at: www.grizzlyranchcsd.com.

For More Information, Contact: Office Administrator Carol Logan or General Manager Larry Smith at phone: 530-832-4716 or email: grizzlyranchcsd@gmail.com.

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1st through December 31, 2021, and may include earlier monitoring data.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Grizzly Ranch CSD a 4456 Grizzly Rd. Portola, CA. 96122, 530-832-4716 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Grizzly Ranch CSD以获得中文的帮助: 4456 Grizzly Rd. Portola, CA 96122, 530-832-4716.

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Grizzly Ranch CSD, 4456 Grizzly Rd. Portola, CA. 96122 o tumawag sa 530-832-4716 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Grizzly Ranch CSD tại 4456 Grizzly Rd. Portola, CA. 96122, 530-832-4716 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Grizzly Ranch CSD ntawm 4456 Grizzly Rd. Portola, CA. 96122, 530-832-4716 rau kev pab hauv lus Askiv.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variations and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
Ppm	parts per million or milligrams per liter (mg/L)
Ppb	parts per billion or milligrams per liter (mg/L)

Term	Definition
Ppt	parts per trillion or nanograms per liter (ng/L)
Ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do

not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (State Total Coliform Rule)	(In a month) 0	0	1 positive monthly sample ^(a)	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (State Total Coliform Rule)	(In the year) 0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive	None	Human and animal fecal waste
<i>E. coli</i> (Federal Revised Total Coliform Rule)	(In the year) 0	0	(b)	0	Human and animal fecal waste

(a) Two or more positive monthly samples is a violation of the MCL

(b) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	7/14/2020 to 7/22/2020	5	.001	0	15	0.2	N/A	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	7/14/2020 to 7/22/20	5	.021	0	1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
								deposits; leaching from wood preservatives

Table 3. Sampling Results for Sodium and Hardness

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	4/14/2020	13		None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	4/14/2020	187		None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
See attachments for breakdowns						

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
See attachments for breakdowns						

--	--	--	--	--	--	--

Table 6. Detection of Unregulated Contaminants

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
See attachments for breakdowns					

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA’s Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Grizzly Ranch CSD is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Additional Special Language for Nitrate, Arsenic, Lead, Radon, and *Cryptosporidium*: [Enter Additional Information Described in Instructions for SWS CCR Document]

Federal Revised Total Coliform Rule (RTCR): [Enter Additional Information Described in Instructions for SWS CCR Document]

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A

For Water Systems Providing Groundwater as a Source of Drinking Water

Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	0	N/A	0	(0)	Human and animal fecal waste
Enterococci	0	N/A	TT	N/A	Human and animal fecal waste
Coliphage	0	N/A	TT	N/A	Human and animal fecal waste

Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT

Special Notice of Fecal Indicator-Positive Groundwater Source Sample: N/A

Special Notice for Uncorrected Significant Deficiencies: N/A

Table 9. Violation of Groundwater TT

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A

For Systems Providing Surface Water as a Source of Drinking Water

Table 10. Sampling Results Showing Treatment of Surface Water Sources

Treatment Technique ^(a) (Type of approved filtration technology used)	N/A
Turbidity Performance Standards ^(b) (that must be met through the water treatment process)	<p>Turbidity of the filtered water must:</p> <p>1 – Be less than or equal to [Enter Turbidity Performance Standard to Be Less Than or Equal to 95% of Measurements in a Month] NTU in 95% of measurements in a month.</p> <p>2 – Not exceed [Enter Turbidity Performance Standard Not to Be Exceeded for More Than Eight Consecutive Hours] NTU for more than eight consecutive hours.</p> <p>3 – Not exceed [Enter Turbidity Performance Standard Not to Be Exceeded at Any Time] NTU at any time.</p>
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	N/A
Highest single turbidity measurement during the year	N/A
Number of violations of any surface water treatment requirements	N/A

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

Summary Information for Violation of a Surface Water TT

Table 11. Violation of Surface Water TT

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A

Summary Information for Operating Under a Variance or Exemption

[Enter Additional Information Described in Instructions for SWS CCR Document]

Summary Information for Federal Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements

Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We did not find coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

During the past year we were required to conduct 0 Level 1 assessment(s). 0 Level 1 assessment(s) were completed. In addition, we were required to take 0 corrective actions and we completed 0 of these actions.

During the past year 0 Level 2 assessments were required to be completed for our water system. 0 Level 2 assessments were completed. In addition, we were required to take 0 corrective actions and we completed 0 of these actions.

[For Violation of the Total Coliform Bacteria TT Requirement, Enter Additional Information Described in Instructions for SWS CCR Document]

Level 2 Assessment Requirement Due to an *E. coli* MCL Violation

E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems. We did not find *E. coli* bacteria, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) identify problems and to correct any problems that were found during these assessments.

We were required to complete 0 Level 2 assessments because we did not *E. coli* in our water system. In addition, we were required to take 0 corrective actions and we completed 0 of these actions.

[For Violation of the *E. coli* TT Requirement, Enter Additional Information Described in Instructions for SWS CCR Document]

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD
Sample Point: WELL 3P2

COUNTY: PLUMAS
CLASS: CTGP STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LESS THAN	REPORTING LEVEL	LAST RESULT	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE
CA3205006_002_002		GRIZZLY RANCH CSD												
		WELL 3P2												
	GP	SECONDARY/GP												
		1928 ALKALINITY, BICARBONATE		0.000	170.000	0.000	MG/L	-----	-----	4/14/2020	2	108		2029/04
		1919 CALCIUM		0.000	47.000	0.000	MG/L	-----	-----	4/14/2020	2	108		2029/04
		1929 ALKALINITY, CARBONATE	<	10.000	0.000	0.000	MG/L	-----	-----	4/14/2020	2	108		2029/04
		1017 CHLORIDE		0.000	2.000	0.000	MG/L	500	-----	4/14/2020	3	108		2029/04
		1905 COLOR		0.000	10.000	0.000	UNITS	15	-----	7/8/2014	3	108		2023/07
		1022 COPPER, FREE	<	50.000	0.000	0.000	UG/L	1000	50	4/14/2020	3	108		2029/04
		2905 FOAMING AGENTS (SURFACTANTS)	<	0.100	0.000	0.000	MG/L	0.5	-----	4/14/2020	3	108		2029/04
		1915 HARDNESS, TOTAL (AS CaCO3)		0.000	187.000	0.000	MG/L	-----	-----	4/14/2020	2	108		2029/04
		1021 HYDROXIDE AS CALCIUM CARBONATE	<	10.000	0.000	0.000	MG/L	-----	-----	4/14/2020	2	108		2029/04
		1028 IRON		100.000	42300.000	0.000	UG/L	300	100	1/18/2022	46	3	Interval	2022/04
		1031 MAGNESIUM		0.000	17.000	0.000	MG/L	-----	-----	4/14/2020	2	108		2029/04
		1032 MANGANESE		20.000	456.000	0.000	UG/L	50	20	1/18/2022	46	3	Interval	2022/04
		1920 ODOR		1.000	32.000	0.000	TON	3	1	7/8/2014	3	108		2023/07
		1925 PH		0.000	7.480	0.000		-----	-----	7/26/2011	4	108		2020/07
		1050 SILVER	<	1.000	0.000	0.000	UG/L	100	10	7/8/2014	4	108		2023/07
		1052 SODIUM		0.000	13.000	0.000	MG/L	-----	-----	4/14/2020	2	108		2029/04
		1064 CONDUCTIVITY @ 25 C UMHOS/CM		0.000	456.000	0.000	US	1600	-----	4/14/2020	3	108		2029/04
		1055 SULFATE		0.500	80.300	0.000	MG/L	500	0.5	4/14/2020	3	108		2029/04
		1930 TDS		0.000	290.000	0.000	MG/L	1000	-----	4/14/2020	5	108		2029/04
		0100 TURBIDITY		0.100	1.100	0.000	NTU	5	0.1	7/8/2014	3	108		2023/07

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 3P2

CLASS: CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LESS THAN	REPORTING LEVEL	LAST RESULT	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE
CA3205006_002_002	GP	SECONDARY/GP												
		1095 ZINC	<	50.000	0.000	0.000	UG/L	5000	50	4/14/2020	3	108		2029/04
	IO	INORGANIC												
		1002 ALUMINUM	<	50.000	0.000	0.000	UG/L	1000	50	7/8/2014	4	108		2023/07
		1074 ANTIMONY, TOTAL	<	1.000	0.000	0.000	UG/L	6	6	7/8/2014	4	108		2023/07
		1005 ARSENIC		2.000	7.000	0.000	UG/L	10	2	1/18/2022	46	108		2031/01
		1010 BARIUM		100.000	58.000	0.000	UG/L	1000	100	7/8/2014	4	108		2023/07
		1075 BERYLLIUM, TOTAL	<	0.200	0.000	0.000	UG/L	4	1	7/8/2014	4	108		2023/07
		1015 CADMIUM	<	1.000	0.000	0.000	UG/L	5	1	7/8/2014	4	108		2023/07
		1020 CHROMIUM		10.000	2.000	0.000	UG/L	50	10	7/8/2014	4	108		2023/07
		1025 FLUORIDE	<	0.100	0.000	0.000	MG/L	2	0.1	4/14/2020	3	108		2029/04
		1035 MERCURY	<	0.200	0.000	0.000	UG/L	2	1	7/8/2014	4	108		2023/07
		1036 NICKEL	<	1.000	0.000	0.000	UG/L	100	10	7/8/2014	4	108		2023/07
		1039 PERCHLORATE	<	4.000	0.000	0.000	UG/L	6	4	4/9/2019	11	36		2022/04
		1045 SELENIUM	<	2.000	0.000	0.000	UG/L	50	5	7/8/2014	4	108		2023/07
		1085 THALLIUM, TOTAL	<	0.500	0.000	0.000	UG/L	2	1	7/8/2014	4	108		2023/07
	NI	NITRATE/NITRITE												
		1040 NITRATE	<	0.400	0.000	0.000	mg/L	10	0.4	4/13/2021	7	12		2022/04
		1041 NITRITE	<	0.400	0.000	0.000	mg/L	1	0.4	4/14/2020	4	36		2023/04
	RA	RADIOLOGICAL												
		4109 GROSS ALPHA PARTICLE ACTIVITY		1.500	0.637	1.120	PCI/L	15	3	1/12/2016	1	108		2025/01
		4030 RADIUM-228		0.200	1.000	0.412	PCI/L	-----	1	2/14/2017	6	108		2026/02

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 3P2

CLASS: CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LESS THAN	REPORTING LEVEL	LAST RESULT	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE
CA3205006_002_002	S1	REGULATED VOC												
		2981 1,1,1-TRICHLOROETHANE	<	0.500	0.000	0.000	UG/L	200	0.5	7/14/2020	2	72		2026/07
		2988 1,1,2,2-TETRACHLOROETHANE	<	0.500	0.000	0.000	UG/L	1	0.5	7/14/2020	2	72		2026/07
		2985 1,1,2-TRICHLOROETHANE	<	0.500	0.000	0.000	UG/L	5	0.5	7/14/2020	2	72		2026/07
		2978 1,1-DICHLOROETHANE	<	0.500	0.000	0.000	UG/L	5	0.5	7/14/2020	2	72		2026/07
		2977 1,1-DICHLOROETHYLENE	<	0.500	0.000	0.000	UG/L	6	0.5	7/14/2020	2	72		2026/07
		2378 1,2,4-TRICHLOROBENZENE	<	0.500	0.000	0.000	UG/L	5	0.5	7/14/2020	2	72		2026/07
		2968 O-DICHLOROBENZENE	<	0.500	0.000	0.000	UG/L	600	0.5	7/14/2020	2	72		2026/07
		2980 1,2-DICHLOROETHANE	<	0.500	0.000	0.000	UG/L	0.5	0.5	7/14/2020	2	72		2026/07
		2983 1,2-DICHLOROPROPANE	<	0.500	0.000	0.000	UG/L	5	0.5	7/14/2020	2	72		2026/07
		2413 1,3-DICHLOROPROPENE	<	0.500	0.000	0.000	UG/L	0.5	0.5	7/14/2020	2	72		2026/07
		2969 P-DICHLOROBENZENE	<	0.500	0.000	0.000	UG/L	5	0.5	7/14/2020	2	72		2026/07
		2990 BENZENE	<	0.500	0.000	0.000	UG/L	1	0.5	7/14/2020	2	72		2026/07
		2982 CARBON TETRACHLORIDE	<	0.500	0.000	0.000	UG/L	0.5	0.5	7/14/2020	2	72		2026/07
		2380 CIS-1,2-DICHLOROETHYLENE	<	0.500	0.000	0.000	UG/L	6	0.5	7/14/2020	2	72		2026/07

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY:

Sample Point:

CLASS. CTGP

STATUS:

PSCODE	GC	GROUP/ANALYTE	LESS THAN	REPORTING LEVEL	LAST RESULT	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE
CA3205006_002_002	S1	2964	DICHLOROMETHANE	<	0.500	0.000	0.000 UG/L	5	0.5	7/14/2020	2	72		2026/07
		2992	ETHYLBENZENE	<	0.500	0.000	0.000 UG/L	300	0.5	7/14/2020	2	72		2026/07
		2251	METHYL TERT-BUTYL ETHER	<	3.000	0.000	0.000 UG/L	13	3	7/14/2020	2	72		2026/07
		2989	CHLOROBENZENE	<	0.500	0.000	0.000 UG/L	70	0.5	7/14/2020	2	72		2026/07
		2996	STYRENE	<	0.500	0.000	0.000 UG/L	100	0.5	7/14/2020	2	72		2026/07
		2987	TETRACHLOROETHYLENE	<	0.500	0.000	0.000 UG/L	5	0.5	7/14/2020	2	72		2026/07
		2991	TOLUENE	<	0.500	0.000	0.000 UG/L	150	0.5	7/14/2020	2	72		2026/07
		2979	TRANS-1,2-DICHLOROETHYLENE	<	0.500	0.000	0.000 UG/L	10	0.5	7/14/2020	2	72		2026/07
		2984	TRICHLOROETHYLENE	<	0.500	0.000	0.000 UG/L	5	0.5	7/14/2020	2	72		2026/07
		2218	TRICHLOROFUOROMETHANE	<	5.000	0.000	0.000 UG/L	150	5	7/14/2020	2	72		2026/07
		2904	TRICHLOROTRIFLUOROETHANE	<	10.000	0.000	0.000 UG/L	1200	10	7/14/2020	2	72		2026/07
		2976	VINYL CHLORIDE	<	0.500	0.000	0.000 UG/L	0.5	0.5	7/14/2020	2	72		2026/07
		2955	XYLENES, TOTAL	<	0.500	0.000	0.000 UG/L	1750	0.5	7/14/2020	2	72		2026/07

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD
Sample Point: WELL 9M

COUNTY: PLUMAS
CLASS: CTGP STATUS: Active

PCODE	GC	GROUP/ANALYTE	LESS THAN	REPORTING LEVEL	LAST RESULT	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE
CA3205006_003_003		GRIZZLY RANCH CSD												
										WELL 9M				
	GP	SECONDARY/GP												
		1928 ALKALINITY, BICARBONATE		0.000	190.000	0.000	MG/L	-----	-----	8/16/2016	2	108		2025/08
		1919 CALCIUM		0.000	62.000	0.000	MG/L	-----	-----	8/16/2016	2	108		2025/08
		1929 ALKALINITY, CARBONATE	<	10.000	0.000	0.000	MG/L	-----	-----	8/16/2016	2	108		2025/08
		1017 CHLORIDE		0.000	1.900	0.000	MG/L	500	-----	8/16/2016	3	108		2025/08
		1905 COLOR		0.000	15.000	0.000	UNITS	15	-----	8/16/2016	3	108		2025/08
		1022 COPPER, FREE	<	1.000	0.000	0.000	UG/L	1000	50	8/16/2016	3	108		2025/08
		2905 FOAMING AGENTS (SURFACTANTS)	<	0.100	0.000	0.000	MG/L	0.5	-----	8/16/2016	3	108		2025/08
		1915 HARDNESS, TOTAL (AS CaCO3)		0.000	208.000	0.000	MG/L	-----	-----	8/16/2016	2	108		2025/08
		1021 HYDROXIDE AS CALCIUM CARBONATE	<	10.000	0.000	0.000	MG/L	-----	-----	8/16/2016	2	108		2025/08
		1028 IRON		100.000	6720.000	0.000	UG/L	300	100	1/18/2022	33	3	Interval	2022/04
		1031 MAGNESIUM		0.000	13.000	0.000	MG/L	-----	-----	8/16/2016	2	108		2025/08
		1032 MANGANESE		20.000	858.000	0.000	UG/L	50	20	1/18/2022	33	3	Interval	2022/04
		1920 ODOR	<	1.000	0.000	0.000	TON	3	1	8/16/2016	3	108		2025/08
		1925 PH		0.000	7.260	0.000		-----	-----	8/16/2016	3	108		2025/08
		1050 SILVER	<	1.000	0.000	0.000	UG/L	100	10	8/16/2016	3	108		2025/08
		1052 SODIUM		0.000	13.000	0.000	MG/L	-----	-----	8/16/2016	2	108		2025/08
		1064 CONDUCTIVITY @ 25 C UMHOS/CM		0.000	250.000	0.000	US	1600	-----	8/16/2016	3	108		2025/08
		1055 SULFATE		0.500	40.000	0.000	MG/L	500	0.5	8/16/2016	3	108		2025/08
		1930 TDS		0.000	210.000	0.000	MG/L	1000	-----	8/16/2016	3	108		2025/08
		0100 TURBIDITY		0.100	4.100	0.000	NTU	5	0.1	8/16/2016	3	108		2025/08
		1095 ZINC		50.000	200.000	0.000	UG/L	5000	50	8/16/2016	3	108		2025/08

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "F", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 9M

CLASS: CTGP

STATUS: Active

PCODE	GC	GROUP/ANALYTE	LESS THAN	REPORTING LEVEL	LAST RESULT	COUNTING ERROR (±)	UDM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE
CA3205006_003_003	IO	INORGANIC												
		1002 ALUMINIUM	<	50.000	0.000	0.000 UG/L	1000	50		8/16/2016	3	108		2025/08
		1074 ANTIMONY, TOTAL	<	1.000	0.000	0.000 UG/L	6	6		8/16/2016	3	108		2025/08
		1005 ARSENIC	<	2.000	0.000	0.000 UG/L	10	2		1/18/2022	33	108		2031/01
		1010 BARIUM		100.000	64.000	0.000 UG/L	1000	100		8/16/2016	3	108		2025/08
		1075 BERYLLIUM, TOTAL	<	1.000	0.000	0.000 UG/L	4	1		8/16/2016	3	108		2025/08
		1015 CADMIUM	<	1.000	0.000	0.000 UG/L	5	1		8/16/2016	3	108		2025/08
		1020 CHROMIUM	<	1.000	0.000	0.000 UG/L	50	10		8/16/2016	3	108		2025/08
		1025 FLUORIDE		0.100	0.140	0.000 MG/L	2	0.1		8/16/2016	3	108		2025/08
		1035 MERCURY	<	2.000	0.000	0.000 UG/L	2	1		8/16/2016	3	108		2025/08
		1036 NICKEL		10.000	1.000	0.000 UG/L	100	10		8/16/2016	3	108		2025/08
		1039 PERCHLORATE	<	4.000	0.000	0.000 UG/L	6	4		4/9/2019	4	36		2022/04
		1045 SELENIUM	<	5.000	0.000	0.000 UG/L	50	5		8/16/2016	3	108		2025/08
		1085 THALLIUM, TOTAL	<	0.500	0.000	0.000 UG/L	2	1		8/16/2016	3	108		2025/08
	NI	NITRATE/NITRITE												
		1040 NITRATE	<	0.400	0.000	0.000 mg/L	10	0.4		4/13/2021	6	12		2022/04
		1041 NITRITE	<	0.400	0.000	0.000 mg/L	1	0.4		4/9/2019	3	36		2022/04
	RA	RADIOLOGICAL												
		4109 GROSS ALPHA PARTICLE ACTIVITY		1.500	0.712	1.180 PCI/L	15	3		8/16/2016	1	108		2025/08
		4030 RADIUM-228		0.200	1.000	0.400 PCI/L	-----	1		2/14/2017	4	108		2026/02

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 9M

CLASS: CTGP

STATUS: Active

PCODE	GC	GROUP/ANALYTE	LESS THAN	REPORTING LEVEL	LAST RESULT	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE
CA3205006_003_003	S1	REGULATED VOC												
		2981 1,1,1-TRICHLOROETHANE	<	0.500	0.000	0.000	UG/L	200	0.5	4/9/2019	2	72		2025/04
		2988 1,1,2,2-TETRACHLOROETHANE	<	0.500	0.000	0.000	UG/L	1	0.5	4/9/2019	2	72		2025/04
		2985 1,1,2-TRICHLOROETHANE	<	0.500	0.000	0.000	UG/L	5	0.5	4/9/2019	2	72		2025/04
		2978 1,1-DICHLOROETHANE	<	0.500	0.000	0.000	UG/L	5	0.5	4/9/2019	2	72		2025/04
		2977 1,1-DICHLOROETHYLENE	<	0.500	0.000	0.000	UG/L	6	0.5	4/9/2019	2	72		2025/04
		2378 1,2,4-TRICHLOROBENZENE	<	0.500	0.000	0.000	UG/L	5	0.5	4/9/2019	2	72		2025/04
		2968 O-DICHLOROBENZENE	<	0.500	0.000	0.000	UG/L	600	0.5	4/9/2019	2	72		2025/04
		2980 1,2-DICHLOROETHANE	<	0.500	0.000	0.000	UG/L	0.5	0.5	4/9/2019	2	72		2025/04
		2983 1,2-DICHLOROPROPANE	<	0.500	0.000	0.000	UG/L	5	0.5	4/9/2019	2	72		2025/04
		2413 1,3-DICHLOROPROPENE	<	0.500	0.000	0.000	UG/L	0.5	0.5	4/9/2019	2	72		2025/04
		2969 P-DICHLOROBENZENE	<	0.500	0.000	0.000	UG/L	5	0.5	4/9/2019	2	72		2025/04
		2990 BENZENE	<	0.500	0.000	0.000	UG/L	1	0.5	4/9/2019	2	72		2025/04
		2982 CARBON TETRACHLORIDE	<	0.500	0.000	0.000	UG/L	0.5	0.5	4/9/2019	2	72		2025/04
		2380 CIS-1,2-DICHLOROETHYLENE	<	0.500	0.000	0.000	UG/L	6	0.5	4/9/2019	2	72		2025/04

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY:

Sample Point:

CLASS: CTGP

STATUS:

PSCODE	GC	GROUP/ANALYTE	LESS THAN	REPORTING LEVEL	LAST RESULT	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MONTHS	MOD	NEXT SAMPLE DUE
CA3205006_003_003	S1	2964	DICHLOROMETHANE	<	0.500	0.000	0.000 UG/L	5	0.5	4/9/2019	2	72		2025/04
		2992	ETHYLBENZENE	<	0.500	0.000	0.000 UG/L	300	0.5	4/9/2019	2	72		2025/04
		2251	METHYL TERT-BUTYL ETHER	<	3.000	0.000	0.000 UG/L	13	3	4/9/2019	2	72		2025/04
		2989	CHLOROBENZENE	<	0.500	0.000	0.000 UG/L	70	0.5	4/9/2019	2	72		2025/04
		2996	STYRENE	<	0.500	0.000	0.000 UG/L	100	0.5	4/9/2019	2	72		2025/04
		2987	TETRACHLOROETHYLENE	<	0.500	0.000	0.000 UG/L	5	0.5	4/9/2019	2	72		2025/04
		2991	TOLUENE	<	0.500	0.000	0.000 UG/L	150	0.5	4/9/2019	2	72		2025/04
		2979	TRANS-1,2-DICHLOROETHYLENE	<	0.500	0.000	0.000 UG/L	10	0.5	4/9/2019	2	72		2025/04
		2984	TRICHLOROETHYLENE	<	0.500	0.000	0.000 UG/L	5	0.5	4/9/2019	2	72		2025/04
		2218	TRICHLOROFLUOROMETHANE	<	5.000	0.000	0.000 UG/L	150	5	4/9/2019	2	72		2025/04
		2904	TRICHLOROTRIFLUOROETHANE	<	10.000	0.000	0.000 UG/L	1200	10	4/9/2019	2	72		2025/04
		2976	VINYL CHLORIDE	<	0.500	0.000	0.000 UG/L	0.5	0.5	4/9/2019	2	72		2025/04
		2955	XYLENES, TOTAL	<	0.500	0.000	0.000 UG/L	1750	0.5	4/9/2019	2	72		2025/04

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 1P

CLASS CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LESS THAN	REPORTING LEVEL	LAST RESULT	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	
CA3205006_001_001		GRIZZLY RANCH CSD													
	GP	SECONDARY/GP								WELL 1P					
		1928	ALKALINITY, BICARBONATE		0.000	80.000	0.000	MG/L	-----	-----	4/18/2017	1	108		2026/04
		1919	CALCIUM		0.000	302.000	0.000	MG/L	-----	-----	4/18/2017	1	108		2026/04
		1929	ALKALINITY, CARBONATE	<	10.000	0.000	0.000	MG/L	-----	-----	4/18/2017	1	108		2026/04
		1017	CHLORIDE		0.000	5.000	0.000	MG/L	500	-----	4/18/2017	4	108		2026/04
		1905	COLOR		0.000	2.500	0.000	UNITS	15	-----	4/14/2020	4	108		2029/04
		1022	COPPER, FREE	<	10.000	0.000	0.000	UG/L	1000	50	4/18/2017	5	108		2026/04
		2905	FOAMING AGENTS (SURFACTANTS)	<	0.100	0.000	0.000	MG/L	0.5	-----	4/18/2017	4	108		2026/04
		1915	HARDNESS, TOTAL (AS CaCO3)		0.000	832.000	0.000	MG/L	-----	-----	4/18/2017	1	108		2026/04
		1021	HYDROXIDE AS CALCIUM CARBONATE	<	10.000	0.000	0.000	MG/L	-----	-----	4/18/2017	1	108		2026/04
		1028	IRON		100.000	6550.000	0.000	UG/L	300	100	1/18/2022	42	3	Interval	2022/04
		1031	MAGNESIUM		0.000	19.000	0.000	MG/L	-----	-----	4/18/2017	1	108		2026/04
		1032	MANGANESE		20.000	1180.000	0.000	UG/L	50	20	1/18/2022	42	3	Interval	2022/04
		1920	ODOR	<	0.000	0.000	0.000	TON	3	-----	4/14/2020	4	108		2029/04
		1925	PH		0.000	7.300	0.000		-----	-----	4/18/2017	4	108		2026/04
		1050	SILVER	<	1.000	0.000	0.000	UG/L	100	10	4/18/2017	5	108		2026/04
		1052	SODIUM		0.000	44.000	0.000	MG/L	-----	-----	4/18/2017	1	108		2026/04
		1064	CONDUCTIVITY @ 25 C UMHOS/CM		0.000	1740.000	0.000	US	1600	-----	4/18/2017	4	108		2026/04
		1055	SULFATE		0.500	990.000	0.000	MG/L	500	0.5	4/18/2017	4	108		2026/04
		1930	TDS		0.000	1510.000	0.000	MG/L	1000	-----	4/18/2017	4	108		2026/04
	0100	TURBIDITY		0.100	7.800	0.000	NTU	5	0.1	4/14/2020	4	108		2029/04	
	1095	ZINC		50.000	280.000	0.000	UG/L	5000	50	4/18/2017	5	108		2026/04	

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 1P

CLASS: CTGP

STATUS: Active

PCODE	GC	GROUP/ANALYTE	LESS THAN	REPORTING LEVEL	LAST RESULT	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE
CA3205006_001_001	IO	INORGANIC												
		1002 ALUMINUM	<	50.000	0.000	0.000	UG/L	1000	50	4/18/2017	5	108		2026/04
		1074 ANTIMONY, TOTAL	<	1.000	0.000	0.000	UG/L	6	6	4/18/2017	5	108		2026/04
		1005 ARSENIC		2.000	23.000	0.000	UG/L	10	2	1/18/2022	42	3	Interval	2022/04
		1010 BARIUM		100.000	17.000	0.000	UG/L	1000	100	4/18/2017	5	108		2026/04
		1075 BERYLLIUM, TOTAL	<	1.000	0.000	0.000	UG/L	4	1	4/18/2017	5	108		2026/04
		1015 CADMIUM	<	0.200	0.000	0.000	UG/L	5	1	4/18/2017	5	108		2026/04
		1020 CHROMIUM	<	1.000	0.000	0.000	UG/L	50	10	4/18/2017	5	108		2026/04
		1025 FLUORIDE	<	0.100	0.000	0.000	MG/L	2	0.1	4/18/2017	4	108		2026/04
		1035 MERCURY	<	1.000	0.000	0.000	UG/L	2	1	4/18/2017	5	108		2026/04
		1036 NICKEL	<	10.000	0.000	0.000	UG/L	100	10	4/18/2017	5	108		2026/04
		1039 PERCHLORATE	<	4.000	0.000	0.000	UG/L	6	4	4/9/2019	6	36		2022/04
		1045 SELENIUM	<	5.000	0.000	0.000	UG/L	50	5	4/18/2017	5	108		2026/04
		1085 THALLIUM, TOTAL	<	1.000	0.000	0.000	UG/L	2	1	4/18/2017	5	108		2026/04
	NI	NITRATE/NITRITE												
		1040 NITRATE	<	0.400	0.000	0.000	mg/L	10	0.4	4/14/2020	6	12		2021/04
		1041 NITRITE	<	0.400	0.000	0.000	mg/L	1	0.4	4/14/2020	4	36		2023/04
	RA	RADIOLOGICAL												
		4109 GROSS ALPHA PARTICLE ACTIVITY		2.600	1.170	1.720	PCI/L	15	3	4/14/2020	2	108		2029/04
		4030 RADIUM-228	<	0.200	0.000	0.445	PCI/L	-----	1	1/7/2014	4	108		2023/01

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 1P

CLASS. CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LESS THAN	REPORTING LEVEL	LAST RESULT	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE
CA3205006_001_001	S1	REGULATED VOC												
		2981 1,1,1-TRICHLOROETHANE	<	0.500	0.000	0.000	UG/L	200	0.5	7/14/2020	2	72		2026/07
		2988 1,1,2,2-TETRACHLOROETHANE	<	0.500	0.000	0.000	UG/L	1	0.5	7/14/2020	2	72		2026/07
		2985 1,1,2-TRICHLOROETHANE	<	0.500	0.000	0.000	UG/L	5	0.5	7/14/2020	2	72		2026/07
		2978 1,1-DICHLOROETHANE	<	0.500	0.000	0.000	UG/L	5	0.5	7/14/2020	2	72		2026/07
		2977 1,1-DICHLOROETHYLENE	<	0.500	0.000	0.000	UG/L	6	0.5	7/14/2020	2	72		2026/07
		2378 1,2,4-TRICHLOROBENZENE	<	0.500	0.000	0.000	UG/L	5	0.5	7/14/2020	2	72		2026/07
		2968 O-DICHLOROBENZENE	<	0.500	0.000	0.000	UG/L	600	0.5	7/14/2020	2	72		2026/07
		2980 1,2-DICHLOROETHANE	<	0.500	0.000	0.000	UG/L	0.5	0.5	7/14/2020	2	72		2026/07
		2983 1,2-DICHLOROPROPANE	<	0.500	0.000	0.000	UG/L	5	0.5	7/14/2020	2	72		2026/07
		2413 1,3-DICHLOROPROPENE	<	0.500	0.000	0.000	UG/L	0.5	0.5	7/14/2020	2	72		2026/07
		2969 P-DICHLOROBENZENE	<	0.500	0.000	0.000	UG/L	5	0.5	7/14/2020	2	72		2026/07
		2990 BENZENE	<	0.500	0.000	0.000	UG/L	1	0.5	7/14/2020	2	72		2026/07
		2982 CARBON TETRACHLORIDE	<	0.500	0.000	0.000	UG/L	0.5	0.5	7/14/2020	2	72		2026/07
		2380 CIS-1,2-DICHLOROETHYLENE	<	0.500	0.000	0.000	UG/L	6	0.5	7/14/2020	2	72		2026/07

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY:

Sample Point:

CLASS: CTGP

STATUS:

PSCODE	GC	GROUP/ANALYTE	LESS THAN	REPORTING LEVEL	LAST RESULT	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE
CA3205006_001_001	S1	2964	DICHLOROMETHANE	<	0.500	0.000	0.000 UG/L	5	0.5	7/14/2020	2	72		2026/07
		2992	ETHYLBENZENE	<	0.500	0.000	0.000 UG/L	300	0.5	7/14/2020	2	72		2026/07
		2251	METHYL TERT-BUTYL ETHER	<	3.000	0.000	0.000 UG/L	13	3	7/14/2020	2	72		2026/07
		2989	CHLOROBENZENE	<	0.500	0.000	0.000 UG/L	70	0.5	7/14/2020	2	72		2026/07
		2996	STYRENE	<	0.500	0.000	0.000 UG/L	100	0.5	7/14/2020	2	72		2026/07
		2987	TETRACHLOROETHYLENE	<	0.500	0.000	0.000 UG/L	5	0.5	7/14/2020	2	72		2026/07
		2991	TOLUENE	<	0.500	0.000	0.000 UG/L	150	0.5	7/14/2020	2	72		2026/07
		2979	TRANS-1,2-DICHLOROETHYLENE	<	0.500	0.000	0.000 UG/L	10	0.5	7/14/2020	2	72		2026/07
		2984	TRICHLOROETHYLENE	<	0.500	0.000	0.000 UG/L	5	0.5	7/14/2020	2	72		2026/07
		2218	TRICHLOROFUOROMETHANE	<	5.000	0.000	0.000 UG/L	150	5	7/14/2020	2	72		2026/07
		2904	TRICHLOROTRIFLUOROETHANE	<	10.000	0.000	0.000 UG/L	1200	10	7/14/2020	2	72		2026/07
		2976	VINYL CHLORIDE	<	0.500	0.000	0.000 UG/L	0.5	0.5	7/14/2020	2	72		2026/07
		2955	XYLENES, TOTAL	<	0.500	0.000	0.000 UG/L	1750	0.5	7/14/2020	2	72		2026/07